



Al-Noor Petroleum
(Pvt.) Limited

intertek
caleb brett



Product Specifications: ENERGO WT 100 (LIGHT) N3

Test	Method	Unit	Result
Appearance	Visual	-	Clear & Bright
Color	ASTM D 1500-12 (2017)	-	L 0.5
Flash Point	ASTM D92-18	°C	190
Pour Point	ASTM D97-17b	°C	-43
Density @ 15 °C	ASTM D4052-18a	Kg/l	0.8481
Viscosity, Kinematic @ 40 °C	ASTM D445-21e1	mm ² /s	11.8
Viscosity, Kinematic @ 100 °C	ASTM D445-21e1	mm ² /s	2.9
Viscosity Index	ASTM D2270-10(2016)	-	89
Saturates, min	ASTM D 7419	wt%	99.9
Aromatics, max	ASTM D 7419	wt%	0.1

Head Office: Plot No. 50-57, Oil Installation Area, Kemari, Karachi, Pakistan.

Tel: +92 (21) 32862801-09. Website: www.alnoor3.com